

Checklist for Special Egress Control Devices

(Section 1003.3.1.10, Uniform Building Code)

The following information is required to be submitted for review of Special Egress Control Devices (SECD). Submittals that are made without the following information will not be approved, and may be returned without review.

- ☐ Provide a floor plan that indicates the locations where the SECD will be installed.
- ☐ Provide an electrical plan that indicates that the device is connected to the smoke detection or sprinkler system and, upon activation of either system, the device shall automatically deactivate.
- ☐ Provide an electrical plan that indicates that the device will automatically deactivate upon the loss of electrical power to any of the following:
 - the device itself;
 - the Smoke detection system; or
 - means of egress illumination.
- ☐ Provide a floor plan that indicates where a switch to unlock the door will be located in an approved location. Acceptable locations are nurse stations, reception counters, etc.
- ☐ The plans shall indicate that a sign will be installed on the door located above and within 12 inches of the panic bar, or other door latching hardware reading:

**KEEP PUSHING. THE DOOR WILL OPEN IN 15 SECONDS.
ALARM WILL SOUND.**

- ☐ Provide manufacturer's catalog information for the device. The following shall be included with the materials:
 - Verification that the device to be installed shall be initiated whenever a manual force of not more than 15 pounds is applied for two seconds to the panic bar, or other door latching hardware.
 - The SECD shall deactivate within 15 seconds, and the time delay shall not be field adjustable.
 - Actuation of the panic bar, or other door-latching hardware devices, shall activate an audible signal at the door.
 - The unlatching shall not require more than one operation.



Construction Review Services

P.O. Box 47852
Olympia, WA
98504-7852

tel: 360-236-2944
fax: 360-236-2901
email: fslcrs@doh.wa.gov

www.doh.wa.gov/crs

Checklist for Special Egress Control Devices